


Chenowith Elementary School

North Wasco County SD 21

Wasc_sch04A

Building Type School	County Wasco	
Street 922 Chenowith Lp Rd		
City The Dalles	State OR	Zip 97058
Latitude 45.62523	Longitude 121.22111	
Tracking Code RVS in 2006	Inspection Date 8/24/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Chenowith Elementary School

Final RVS Score

Final Type	Final Score
C2	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Chenowith Elementary School

Wasc_sch04A

Enrollment 417	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 38214	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards Unreinforced Chimneys Other: Ornamental Hazard Over Exit None		Poor Conditions None None None	
			
NW Plan Irregularity Primary		NW Plan Irregularity Primary	SW Pounding Potential a on left b on rght
			
SE Elevation View		SE Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Chenowith Elementary School

North Wasco County SD 21

Wasc_sch04B

Building Type School	County Wasco	
Street 922 Chenowith Lp Rd		
City The Dalles	State OR	Zip 97058
Latitude 45.62532	Longitude 121.22191	
Tracking Code RVS in 2006	Inspection Date 8/24/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Chenowith Elementary School

Final RVS Score

Final Type	Final Score
C2	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Chenowith Elementary School

Wasc_sch04B

Enrollment 417	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 38214	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Ornamental Hazard Over Exit		None	
None		None	
None		None	
NW Elevation View	NW Plan Irregularity Primary inside of u	E Elevation View inside of w arm	
W Elevation View inside of e arm	NE Elevation View	SE Elevation View	
E Elevation View	S Elevation View	N Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries