

The Dalles-Wahtonka High School (The Dalles Camp)

North Wasco County SD 21

Wasc_sch07A

Building Type	County
School	Wasco
Street	
3601 W 10th St	
City	State Zip
The Dalles	OR 97058
Latitude	Longitude
45.62533	121.22539
Tracking Code	Inspection Date
RVS in 2006	8/24/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary		0	0	0	0	0	0	0	0	0

The Dalles-Wahtonka High School
(The Dalles Campus)

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

The Dalles-Wahtonka High School (The Dalles Campus)

Wasc_sch07A

Enrollment 253	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1960
Total Area (square ft) 	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards Unreinforced Chimneys Other: Ornamental Hazard Over Exit None		Poor Conditions None None None	
			
NW Elevation View	W Primary Structural Type solid jts	W Field Verified Year Built 1965	
			
W Building Name	W Vertical Irregularity Primary	SW Vertical Irregularity Primary	
			
S Plan Irregularity Primary and chimney	S Secondary Structural Type c2 gym and small rm1 addn	E Secondary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries



E Elevation View



NE Pounding Potential
and rm/c2 boundary

The Dalles-Wahtonka High School (The Dalles Camp)

North Wasco County SD 21

Wasc_sch07B

Building Type	County
School	Wasco
Street	
3601 W 10th St	
City	State Zip
The Dalles	OR 97058
Latitude	Longitude
45.62523	121.22443
Tracking Code	Inspection Date
RVS in 2006	8/24/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	3.2	0	0	0	0	-0.6	0	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

**The Dalles-Wahtonka High School
(The Dalles Campus)**

Final RVS Score

Final Type	Final Score
PC1	2.6

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

The Dalles-Wahhtonka High School (The Dalles Campus)

Wasc_sch07B

Enrollment 253	Year Built (Field Verified) 1994	Year Built (Alt. Source) 1965	Est. Decade Built 1990
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Other: Ornamental Hazard Over Exit		Poor Conditions None None None	
			
W Pounding Potential	N Primary Structural Type caulked jts	N Field Verified Year Built 1994	
			
NE Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries