

# Hillsboro Fire & Rescue

City of Hillsboro

Wash\_fir03A

|                              |                              |              |
|------------------------------|------------------------------|--------------|
| Building Type<br>Fire - City | County<br>Washington         |              |
| Street<br>5045 Se Drake Rd   |                              |              |
| City<br>Hillsboro            | State<br>OR                  | Zip<br>97123 |
| Latitude<br>45.50304         | Longitude<br>122.93062       |              |
| Tracking Code<br>RVS in 2006 | Inspection Date<br>7/10/2006 |              |



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | W2   | 3.8         | -2         | 0          | 0        | 2.4        | -0.4   | 0      | 0      | 3.8       |
| Secondary |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

Hillsboro Fire & Rescue

## Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| W2         | 3.8         |

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Hillsboro Fire & Rescue

Wash\_fir03A

|   |                               |   |                         |
|---|-------------------------------|---|-------------------------|
| Enrollment  | Year Built (Field Verified)   | Year Built (Alt. Source)  | Est. Decade Built       |
|   |                               |   | 1980                    |
| Total Area (square ft)  | Number of Stories             | Basement  | Pounding Potential      |
|   | 1                             | No  | No                      |
| Plan Irregularities   |                               | Vertical Irregularities   |                         |
| None  |                               | Steps in Elevation View: Single Change  |                         |
| None  |                               | None  |                         |
| None  |                               | None  |                         |
| Falling Hazards   |                               | Poor Conditions   |                         |
| None  |                               | None  |                         |
| None  |                               | None  |                         |
| None  |                               | None  |                         |
|     |                               |    |                         |
| SE  | General Site                  | E   | Primary Structural Type |
|   |                               |  |                         |
| NE  | General Site                  | NE  | General Site            |
|    |                               |   |                         |
| N   | Vertical Irregularity Primary | W   | General Site            |
|  |                               |  |                         |
| NW  | General Site                  | NW  | General Site            |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries