

TVF & R - Station 68 Oak Hills (House)

Tualatin Valley F&R

Wash_fir05A

Building Type	County	
Fire - RFPD	Washington	
Street		
3260 Nw 147th Pl		
City	State	Zip
Portland	OR	97229
Latitude	Longitude	
45.54338	122.82843	
Tracking Code	Inspection Date	
To be Re-built	6/30/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

TVF & R - Station 68 Oak Hills (House)

Final RVS Score

Final Type	Final Score
W1	4.4

FEMA-154 Collapse Potential

Low (<1%)



TVF & R - Station 68 Oak Hills (House)

Wash_fir05A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1970	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
2328	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
Other: Ornamental Hazard Over Exit		None	
			
SW General Site		SE Falling Hazard	
		E Falling Hazard Short Chimney may not be considered a falling hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

TVF & R - Station 68 Oak Hills (Apparatus)

Tualatin Valley F&R

Wash_fir05B

Building Type Fire - RFPD	County Washington	
Street 3260 Nw 147th Pl		
City Portland	State OR	Zip 97229
Latitude 45.5434	Longitude 122.82808	
Tracking Code To be Re-built	Inspection Date 6/30/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	-0.4	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

TVF & R - Station 68 Oak Hills
(Apparatus)

Final RVS Score

Final Type	Final Score
S3	2.8

FEMA-154 Collapse Potential

Low (<1%)



TVF & R - Station 68 Oak Hills (Apparatus)

Wash_fir05B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1970	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
882	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE	Primary Structural Type		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries