


TVF & R - Station xx Sherwood

Tualatin Valley F&R

Wash_fir13A

Building Type Fire - RFPD	County Washington	
Street 12400 Sw Tonquin Rd		
City Sherwood	State OR	Zip 97140
Latitude 45.34536	Longitude 122.80509	
Tracking Code RVS in 2006	Inspection Date 7/3/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

TVF & R - Station xx Sherwood

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

TVF & R - Station xx Sherwood

Wash_fir13A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1992	1992	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Heavy cornice or other overhead decoration		None	
None		None	
None		None	
			
S	General Site	E	Plan Irregularity Primary
			
E	Building Name		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

TVF & R - Station xx Sherwood

Tualatin Valley F&R

Wash_fir13B

Building Type Fire - RFPD	County Washington	
Street 12400 Sw Tonquin Rd		
City Sherwood	State OR	Zip 97140
Latitude 45.34527	Longitude 122.80428	
Tracking Code RVS in 2006	Inspection Date 7/3/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	0	0	0	2.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

TVF & R - Station xx Sherwood

Final RVS Score

Final Type	Final Score
S3	2.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

TVF & R - Station xx Sherwood

Wash_fir13B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1992	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	Yes
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries