

# TVF & R - Station 34 Tualatin

Tualatin Valley F&R

Wash\_fir21A

Building Type Fire - RFPD	County Washington	
Street 19365 Sw 90th Ct		
City Tualatin	State OR	Zip 97062
Latitude 45.37976	Longitude 122.77089	
Tracking Code To be Retrofit	Inspection Date 7/3/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


TVF & R - Station 34 Tualatin

## Final RVS Score

Final Type	Final Score
RM1	1.7

## FEMA-154 Collapse Potential

Low (<1%)



Oregon Geology

# TVF & R - Station 34 Tualatin

Wash\_fir21A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1990	1990	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
8184	1	No	No
Plan Irregularities		Vertical Irregularities	
Lateral-Force-Resistance in One Direction Only		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	



SW Elevation View



SW Primary Structural Type



E Field Verified Year Built  
1990



NE Elevation View



E Building Name



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries