

# Hillsboro Fire Dept

City of Hillsboro

Wash\_fir26A

Building Type		County	
Fire - City		Washington	
Street			
275 Ne 25th Ave			
City	State	Zip	
Hillsboro	OR	97124	
Latitude		Longitude	
45.52378		122.95685	
Tracking Code		Inspection Date	
RVS in 2006		7/10/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hillsboro Fire Dept

## Final RVS Score

Final Type

Final Score

W1

1.4

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Torsion: Eccentric Stiffness	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None




N Vertical Irregularity Primary

SW Primary Structural Type  
Wood

SE General Site



SW Plan Irregularity Primary



NW Vertical Irregularity Primary



N Building Name