

Forest Grove Fire & Rescue

City of Forest Grove

Wash_fir28A

Building Type		County	
Fire - City		Washington	
Street			
52155 NW Gales Creek Rd			
City	State	Zip	
Gales Creek	OR	97117	
Latitude		Longitude	
45.58517		123.21402	
Tracking Code		Inspection Date	
RVS in 2006		7/13/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Forest Grove Fire & Rescue

Final RVS Score

Final Type

Final Score

S3

2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE Building Name



NW Primary Structural Type



W General Site

