

Washington County Jail and Sheriff's Office

Washington County

Wash_pol02A

Building Type Police - County	County Washington	
Street 215 SW Adams Ave		
City Hillsboro	State OR	Zip 97123
Latitude 45.52093	Longitude 122.99344	
Tracking Code RVS in 2006	Inspection Date 12/30/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	C1	2.5	-1.5	-0.5	0	0	-0.4	0	0	0.1
Tertiary		0	0	0	0	0	0	0	0	0

Washington County Jail and Sheriff's Office

Final RVS Score

Final Type	Final Score
C1	0.1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Washington County Jail and Sheriff's Office

Wash_pol02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Plan Irregularity Primary		NW Vertical Irregularity Primary	
			
NE Plan Irregularity Primary		NE Elevation View	
			
NW Vertical Irregularity Primary		NW Elevation View	
			
E Building Name		E Primary Structural Type precast or cladding?	
			
E Primary Structural Type precast or cladding?		E Primary Structural Type precast or cladding?	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Washington County Jail and Sheriff's Office

Wash_pol02A



SE Elevation View



SE Plan Irregularity Primary