

Building Type		County	
Police - County		Washington	
Street			
3700 SW Murray Blvd			
City	State	Zip	
Beaverton	OR	97005	
Latitude		Longitude	
45.49339		122.82546	
Tracking Code		Inspection Date	
RVS in 2006		6/27/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Washington County Sheriff's Office

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)




Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	3	No	Yes

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Building On Hill or Sloped Site
None	Steps in Elevation View: 2 to 3 Changes
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Plan Irregularity Primary




W Plan Irregularity Primary




W Pounding Potential



W Pounding Potential

W Pounding Potential
concrete walkway up against w2 str.

W Building Name

S Vertical Irregularity Primary
Sloped hill. The first floor in picture is completely buried in back side

S General Site

W Pounding Potential
Looking up where walkway meets building.