

Hillsboro Sheriff - Jail

City of Hillsboro

Wash_pol16A

Building Type Police - City	County Washington	
Street 20795 NW Cornell Rd Suite 1		
City Hillsboro	State OR	Zip 97124
Latitude 45.53982	Longitude 122.89091	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hillsboro Sheriff - Jail

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hillsboro Sheriff - Jail

Wash_pol16A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Heavy cornice or other overhead decoration		None	
None		None	
None		None	
			
SW	Primary Structural Type	S	Falling Hazard
			
NW	Elevation View	NW	Elevation View
			
NE	Elevation View	SE	Elevation View
			
S	Building Name	SE	Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries