

# Eastwood Elementary School

Hillsboro SD 1J

Wash\_sch03A

Building Type	County	
School	Washington	
Street		
2100 Ne Lincoln St		
City	State	Zip
Hillsboro	OR	97124
Latitude	Longitude	
45.52362	122.95981	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eastwood Elementary School

### Final RVS Score

Final Type	Final Score
W2	0.5

### FEMA-154 Collapse Potential

High (>10%)

No  
Planview  
Available



OregonGeology

# Eastwood Elementary School

Wash\_sch03A

Enrollment 505	Year Built (Field Verified) 1977	Year Built (Alt. Source) 1977	Est. Decade Built
Total Area (square ft) 45963	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	