

Peter Boscow Elementary School

Hillsboro SD 1J

Wash_sch06A

| | | |
|-------------------------------|-----------------|-------|
| Building Type | County | |
| School | Washington | |
| Street | | |
| 452 Ne 3rd Ave | | |
| City | State | Zip |
| Hillsboro | OR | 97124 |
| Latitude | Longitude | |
| 45.52727 | 122.98558 | |
| Tracking Code | Inspection Date | |
| Structural Engineering Report | 9/15/2006 | |



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | C2 | 2.8 | -1 | -0.5 | -1 | 0 | 0 | -0.6 | 0 | -0.3 |
| Secondary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Peter Boscow Elementary School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| C2 | -0.3 |

FEMA-154 Collapse Potential

Very High (100%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Peter Boscow Elementary School

Wash_sch06A

| | | | |
|---------------------------------|-------------------------------------|----------------------------------|--------------------------|
| Enrollment 388 | Year Built (Field Verified) 1922 | Year Built (Alt. Source) 1922 | Est. Decade Built |
| Total Area (square ft) 60750 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities | | Vertical Irregularities | |
| | | | |
| | | | |
| | | | |
| Falling Hazards | | Poor Conditions | |
| | | | |
| | | | |
| | | | |