

Building Type School	County Washington	
Street 8111 Sw West Slope Dr		
City Portland	State OR	Zip 97225
Latitude 45.50466	Longitude 122.76075	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

West Sylvan Middle School

Final RVS Score	
Final Type	Final Score
W2	0.9
FEMA-154 Collapse Potential	
High (>10%)	

No
Planview
Available



West Sylvan Middle School

Wash_sch117A

Enrollment 878	Year Built (Field Verified) 1954	Year Built (Alt. Source) 1954	Est. Decade Built
Total Area (square ft) 102209	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries