

Building Type School	County Washington									
Street 1060 SE 24th Ave										
City Hillsboro	State OR	Zip 97123								
Latitude 45.512	Longitude 122.9566									
Tracking Code Already Retrofitted	Inspection Date 9/15/2006									
Seismicity Zone: High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

W L Henry Elementary School

Final RVS Score

Final Type W2	Final Score 0.5
------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)



No
Planview
Available



W L Henry Elementary School

Wash_sch12A

Enrollment 616	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built
Total Area (square ft) 48813	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries