

McKay Elementary School

Beaverton SD 48J

Wash_sch15A

Building Type		County	
School		Washington	
Street			
7485 Sw Scholls Ferry Rd			
City	State	Zip	
Beaverton	OR	97008	
Latitude		Longitude	
45.46543		122.77828	
Tracking Code		Inspection Date	
Already Retrofitted		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McKay Elementary School

Final RVS Score

Final Type

Final Score

W2

-0.1

FEMA-154 Collapse Potential

Moderate (>1%)

No Planview Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
388		1929	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
49010	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions