

McKinley Elementary School

Beaverton SD 48J

Wash_sch18A

Building Type	County	
School	Washington	
Street		
1500 Nw 185th Ave		
City	State	Zip
Beaverton	OR	97006
Latitude		Longitude
45.53018		122.86658
Tracking Code		Inspection Date
Structural Engineering Report		9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McKinley Elementary School

Final RVS Score

Final Type

Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
552		1955	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
45893	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions