

Building Type School	County Washington	
Street 3285 Se Rood Bridge Rd		
City Hillsboro	State OR	Zip 97123
Latitude 45.49496	Longitude 122.95911	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hillsboro High School

Final RVS Score

Final Type	Final Score
PC1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Oregon Geology

Hillsboro High School

Wash_sch19A

Enrollment 1474	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built
Total Area (square ft) 256652	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	