

# Butternut Creek Elementary School

Hillsboro SD 1J

Wash\_sch39A

Building Type	County	
School	Washington	
Street		
20395 Sw Florence St		
City	State	Zip
Aloha	OR	97007
Latitude	Longitude	
45.48712	122.88687	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Butternut Creek Elementary School

### Final RVS Score

Final Type	Final Score
W2	0.5

### FEMA-154 Collapse Potential

Moderate (>1%)

No  
Planview  
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Butternut Creek Elementary School

Wash\_sch39A

Enrollment 442	Year Built (Field Verified) 1977	Year Built (Alt. Source) 1977	Est. Decade Built
Total Area (square ft) 42638	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries