

Reedville Elementary School

Hillsboro SD 1J

Wash_sch41A

Building Type	County	
School	Washington	
Street		
2695 Sw 209th Ave		
City	State	Zip
Aloha	OR	97006
Latitude	Longitude	
45.50003	122.89203	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Reedville Elementary School

Final RVS Score

Final Type	Final Score
W2	-0.5

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Reedville Elementary School

Wash_sch41A

Enrollment 352	Year Built (Field Verified) 1922	Year Built (Alt. Source) 1922	Est. Decade Built
Total Area (square ft) 16247	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	