

Ladd Acres Elementary School

Hillsboro SD 1J

Wash_sch42A

Building Type		County	
School		Washington	
Street			
2425 Sw Cornelius Rd			
City	State	Zip	
Hillsboro	OR	97123	
Latitude		Longitude	
45.50219		122.90333	
Tracking Code		Inspection Date	
Already Retrofitted		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Ladd Acres Elementary School

Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
603		1967	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
60825	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions

