

Witch Hazel Elementary School

Hillsboro SD 1J

Wash_sch43A

Building Type	County	
School	Washington	
Street		
4950 Sw Davis Rd		
City	State	Zip
Hillsboro	OR	97123
Latitude	Longitude	
45.49359	122.9324	
Tracking Code	Inspection Date	
New Building	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	2.4	-0.4	0	0	4.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Witch Hazel Elementary School

Final RVS Score

Final Type	Final Score
C2	4.8

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Witch Hazel Elementary School

Wash_sch43A

Enrollment 489	Year Built (Field Verified) 2004	Year Built (Alt. Source) 2004	Est. Decade Built
Total Area (square ft) 18440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries