

Building Type	County	
School	Washington	
Street		
7670 Sw 170Th Ave		
City	State	Zip
Beaverton	OR	97007
Latitude	Longitude	
45.46453	122.85073	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cooper Mountain Elementary School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Cooper Mountain Elementary School

Wash_sch51A

Enrollment 541	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built
Total Area (square ft) 51935	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries