

Errol Hassell Elementary School

Beaverton SD 48J

Wash_sch52A

Building Type	County
School	Washington
Street	
18100 Sw Bany Rd	
City	State Zip
Beaverton	OR 97007
Latitude	Longitude
45.46626	122.86318
Tracking Code	Inspection Date
Structural Engineering Report 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Errol Hassell Elementary School

Final RVS Score

Final Type	Final Score
PC1	2.1

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Errol Hassell Elementary School

Wash_sch52A

Enrollment 499	Year Built (Field Verified) 1979	Year Built (Alt. Source) 1979	Est. Decade Built
Total Area (square ft) 52430	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	