

Vose Elementary School

Beaverton SD 48J

Wash_sch64A

Building Type		County	
School		Washington	
Street			
11350 Sw Denney Rd			
City	State	Zip	
Beaverton	OR	97008	
Latitude		Longitude	
45.46864		122.79381	
Tracking Code		Inspection Date	
Already Retrofitted		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Vose Elementary School

Final RVS Score

Final Type

Final Score

RM1

0.9

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
542		1960	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
51520	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site