

Building Type School	County Washington									
Street 14100 Sw Downing St										
City Beaverton	State OR	Zip 97006								
Latitude 45.51526	Longitude 122.8234									
Tracking Code Already Retrofitted	Inspection Date 9/15/2006									
Seismicity Zone: High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Meadow Park Middle School

Final RVS Score

Final Type PC1	Final Score 1.7
-------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)



No
Planview
Available



Meadow Park Middle School

Wash_sch69A

Enrollment 859	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 121777	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	