

Highland Park Middle School

Beaverton SD 48J

Wash_sch71A

Building Type	County	
School	Washington	
Street		
7000 Sw Wilson Ave		
City	State	Zip
Beaverton	OR	97008
Latitude	Longitude	
45.46898	122.81859	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Highland Park Middle School

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Highland Park Middle School

Wash_sch71A

Enrollment 1009	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built
Total Area (square ft) 121777	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site		
			
S	General Site		