

Building Type School	County Washington	
Street 18550 Sw Kinnaman Rd		
City Beaverton	State OR	Zip 97007
Latitude 45.48474	Longitude 122.86894	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Aloha High School

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Oregon Geology

Aloha High School

Wash_sch72A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
2002		1967	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
232200	1	No	No

Plan Irregularities

Vertical Irregularities

Falling Hazards

Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site

