

# Sunset High School

Beaverton SD 48J

Wash\_sch74A

Building Type School	County Washington	
Street 13840 Nw Cornell Rd		
City Portland	State OR	Zip 97229
Latitude 45.52795	Longitude 122.8198	
Tracking Code Already Retrofitted	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sunset High School

## Final RVS Score

Final Type	Final Score
W2	0.9

## FEMA-154 Collapse Potential

Moderate (>1%)

No  
Planview  
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Sunset High School

Wash\_sch74A

Enrollment 2130	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built
Total Area (square ft) 217068	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries