

North Plains Elementary School

Hillsboro SD 1J

Wash_sch76A

| | | |
|-------------------------------|-----------------|-------|
| Building Type | County | |
| School | Washington | |
| Street | | |
| 32030 Nw North Ave | | |
| City | State | Zip |
| North Plains | OR | 97133 |
| Latitude | Longitude | |
| 45.60171 | 123.0067 | |
| Tracking Code | Inspection Date | |
| Structural Engineering Report | 9/15/2006 | |



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | C2 | 2.8 | -1 | -0.5 | 0 | 0 | 0 | -0.6 | 0 | 0.7 |
| Secondary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

North Plains Elementary School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| C2 | 0.7 |

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

North Plains Elementary School

Wash_sch76A

| | | | |
|--|-------------------------------------|--|--------------------------|
| Enrollment 310 | Year Built (Field Verified) 1954 | Year Built (Alt. Source) 1954 | Est. Decade Built |
| Total Area (square ft) 46913 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities | | Vertical Irregularities | |
| | | | |
| | | | |
| | | | |
| Falling Hazards | | Poor Conditions | |
| | | | |
| | | | |
| | | | |
|  | |  | |
| S General Site | | S General Site | |
|  | | | |
| S General Site | | | |
|  | |  | |
| S General Site | | S General Site | |