

Gaston Jr/Sr High School

Gaston SD 511J

Wash_sch81A

Building Type School	County Washington	
Street 304 Park St		
City Gaston	State OR	Zip 97119
Latitude 45.43533	Longitude 123.14392	
Tracking Code RVS in 2006	Inspection Date 7/6/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Tertiary		0	0	0	0	0	0	0	0	0

Gaston Jr/Sr High School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential


High (>10%)



OregonGeology

Gaston Jr/Sr High School

Wash_sch81A

Enrollment 277	Year Built (Field Verified) 1987	Year Built (Alt. Source) 1987	Est. Decade Built 1970
Total Area (square ft) 16766	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Building On Hill or Sloped Site Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Falling Hazards None None None		Poor Conditions None None None	
 NE General Site		 NE General Site	
		 S General Site	
 SW Building Name			

Gaston Jr/Sr High School

Gaston SD 511J

Wash_sch81B

Building Type	County
School	Washington
Street	
304 Park St	
City	State Zip
Gaston	OR 97119
Latitude	Longitude
45.4356	123.144
Tracking Code	Inspection Date
RVS in 2006	7/6/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Gaston Jr/Sr High School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Gaston Jr/Sr High School

Wash_sch81B

Enrollment 277	Year Built (Field Verified) 1987	Year Built (Alt. Source) 1987	Est. Decade Built 1970
Total Area (square ft) 16766	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards Parapets: General None None		Poor Conditions None None None	
 SE Elevation View		 SE Primary Structural Type	
 NW Elevation View		 NW General Site	
 W Pounding Potential AB			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries