

Building Type School	County Washington	
Street 1505 Sw Cornelius Pass Rd		
City Hillsboro	State OR	Zip 97123
Latitude 45.50956	Longitude 122.90307	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

R A Brown Middle School

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

R A Brown Middle School

Wash_sch82A

Enrollment 875	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 94215	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	