

Building Type School	County Washington	
Street 29850 Nw Evergreen Rd		
City Hillsboro	State OR	Zip 97124
Latitude 45.5483	Longitude 122.98496	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evergreen Jr High School

## Final RVS Score

Final Type	Final Score
PC1	1.5

## FEMA-154 Collapse Potential

Moderate (&gt;1%)

No  
Planview  
Available



OregonGeology

# Evergreen Jr High School

Wash\_sch83A

Enrollment 778	Year Built (Field Verified) 1980	Year Built (Alt. Source) 1980	Est. Decade Built
Total Area (square ft) 120000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	