

Building Type School	County Washington	
Street 2700 Nw Glencoe Rd		
City Hillsboro	State OR	Zip 97124
Latitude 45.542	Longitude 122.99282	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC2	2.4	-1	-0.5	0	0	-0.4	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Glencoe High School

## Final RVS Score

Final Type	Final Score
PC2	0.5

## FEMA-154 Collapse Potential

High (&gt;10%)

No  
Planview  
Available



Oregon Geology

# Glencoe High School

Wash\_sch84A

Enrollment 1443	Year Built (Field Verified) 1979	Year Built (Alt. Source) 1979	Est. Decade Built
Total Area (square ft) 249600	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	