

Jackson Elementary School

Hillsboro SD 1J

Wash_sch86A

Building Type	County	
School	Washington	
Street		
675 Ne Estate Dr		
City	State	Zip
Hillsboro	OR	97124
Latitude	Longitude	
45.54376	122.98152	
Tracking Code	Inspection Date	
Already Retrofitted	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jackson Elementary School

Final RVS Score

Final Type	Final Score
W2	2.9

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Jackson Elementary School

Wash_sch86A

Enrollment 656	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built
Total Area (square ft) 48367	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	