

Tobias Elementary School

Hillsboro SD 1J

Wash_sch89A

Building Type		County	
School		Washington	
Street			
1065 SW 206th			
City	State	Zip	
Aloha	OR	97006	
Latitude		Longitude	
45.51214		122.89064	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Tobias Elementary School

Final RVS Score

Final Type

Final Score

W2

2.9

FEMA-154 Collapse Potential

Low (<1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
563		1992	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
52650	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions