

Spray School

Spray SD 1

Whee_sch01A

Building Type School	County Wheeler	
Street 303 Park		
City Spray	State OR	Zip 97874
Latitude 44.83423	Longitude 119.79282	
Tracking Code RVS in 2006	Inspection Date 7/26/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	0	-0.8	0	0.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Spray School

Final RVS Score

Final Type	Final Score
URM	0.2


FEMA-154 Collapse Potential

High (>10%)



Spray School

Whee_sch01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
66	1920	1955	1920
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
3026	1	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: T shaped		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Field Verified Year Built	W	Seismic Upgrade
			
E	Seismic Upgrade	E	Plan Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Spray School

Spray SD 1

Whee_sch01B

Building Type	County
School	Wheeler
Street	
303 Park	
City	State Zip
Spray	OR 97874
Latitude	Longitude
44.83449	119.7926
Tracking Code	Inspection Date
RVS in 2006	7/26/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Tertiary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1

Spray School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Spray School

Whee_sch01B

Enrollment 66	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 3026	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Plan Irregularity Primary		E Vertical Irregularity Primary	
		NE Tertiary Structural Type	
			
N Vertical Irregularity Secondary		W Secondary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Spray School

Spray SD 1

Whee_sch01C

Building Type	County	
School	Wheeler	
Street		
303 Park		
City	State	Zip
Spray	OR	97874
Latitude	Longitude	
44.83463	119.79318	
Tracking Code	Inspection Date	
RVS in 2006	7/26/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Spray School

Final RVS Score

Final Type

RM1

Final Score

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Spray School

Whee_sch01C

Enrollment 66	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 3026	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Internal Discontinuous Diaphragm (large internal opening) None None	
Falling Hazards None None None		Poor Conditions None None None	
 SW Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Spray School

Spray SD 1

Whee_sch01D

Building Type School	County Wheeler	
Street 303 Park		
City Spray	State OR	Zip 97874
Latitude 44.83375	Longitude 119.7927	
Tracking Code RVS in 2006	Inspection Date 7/26/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	0	-1.2	0	0.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Spray School

Final RVS Score

Final Type	Final Score
RM1	0.4

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Spray School

Whee_sch01D

Enrollment 66	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1955	Est. Decade Built 1960
Total Area (square ft) 3026	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W Plan Irregularity Primary		NE Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries