

Wheeler High School

Fossil SD 21J

Whee_sch03A

Building Type	County
School	Wheeler
Street	
600 B St	
City	State Zip
Fossil	OR 97830
Latitude	Longitude
45.0015	120.21335
Tracking Code	Inspection Date
RVS in 2006	7/26/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary		0	0	0	0	0	0	0	0	0

Wheeler High School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Wheeler High School

Whee_sch03A

Enrollment 26	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1940	Est. Decade Built 1940
Total Area (square ft) 21088	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions Cracks None None	
 SW Vertical Irregularity Primary		 NE Poor Condition	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries