

# Fossil Elementary School

Whee\_sch04A

Fossil SD 21J

Building Type		County	
School		Wheeler	
Street			
404 Main St			
City	State	Zip	
Fossil	OR	97830	
Latitude		Longitude	
45.00029		120.21327	
Tracking Code		Inspection Date	
RVS in 2006		7/26/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	-0.4	0	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Fossil Elementary School

## Final RVS Score

Final Type

Final Score

URM

0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
64		1925	1900
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
23680	1	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: E Shaped	Steps in Elevation View: Single Change
None	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None



SE Elevation View



NE Falling Hazard



# Fossil Elementary School

Whee\_sch04B

Fossil SD 21J

Building Type		County	
School		Wheeler	
Street			
404 Main St			
City	State	Zip	
Fossil	OR	97830	
Latitude		Longitude	
45.00028		120.21303	
Tracking Code		Inspection Date	
RVS in 2006		7/26/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	-0.2	0	-0.8	0	0	0.3
Secondary	RM1	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Fossil Elementary School

## Final RVS Score

Final Type

Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
64		1925	1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
23680	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None

N General Site

