

# Lafayette FD

City of Lafayette

Yamh\_fir08A

Building Type	County	
Fire - City	Yamhill	
Street		
486 3rd St		
City	State	Zip
Lafayette	OR	97127
Latitude	Longitude	
45.24393	123.11323	
Tracking Code	Inspection Date	
RVS in 2006	8/9/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	-1	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lafayette FD

## Final RVS Score


Final Type	Final Score
RM1	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:L shaped (Adjacent Build/Entity)		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		Cracks	
None		Differential Settlement with Damage	
None		None	
	W Poor Condition		SW Elevation View
	SE Elevation View		
	E Building Name		E Poor Condition
	E Pounding Potential Wood bldg on right.		
	SW Falling Hazard		



# Lafayette FD

City of Lafayette

Yamh\_fir08B

Building Type Fire - City	County Yamhill	
Street 486 3rd St		
City Lafayette	State OR	Zip 97127
Latitude 45.24404	Longitude 123.11319	
Tracking Code RVS in 2006	Inspection Date 8/9/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	0	-0.8	0	2.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lafayette FD

## Final RVS Score

Final Type	Final Score
W2	2.5


## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:L shaped (Adjacent Build/Entity)		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
 NE Other		 SW Primary Structural Type wood	
		 SW Plan Irregularity Primary	
 NW Elevation View			

