

City of Newberg

Building Type Police - City	County Yamhill
Street 1502 N Highway 99W	
City McMinnville	State OR
Latitude 45.22604	Longitude 123.18277
Tracking Code RVS in 2006	Inspection Date 8/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Newberg - Dundee Police and 911 Center

Final RVS Score

Final Type	Final Score
W1	1.4

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Newberg - Dundee Police and 911 Center

Yamh_pol06A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Building Name		W Elevation View	
		NW Vertical Irregularity Primary	
			
N Elevation View		SE Elevation View	
		SW Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries