

Sheridan Sheriff's Office

Yamhill County

Yamh_pol07A

Building Type Police - County	County Yamhill	
Street 120 Sw Mill St		
City Sheridan	State OR	Zip 97378
Latitude 45.0967	Longitude 123.39576	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sheridan Sheriff's Office

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sheridan Sheriff's Office

Yamh_pol07A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1940	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



NW Vertical Irregularity Primary



NW Primary Structural Type



NE Building Name



NE Plan Irregularity Primary



SE Plan Irregularity Primary



NE Building Quality
single pane windows



E Building Quality
Covered soffits = newer bldg?



SW Vertical Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries