

OSP

Oregon State Police

Yamh_pol08A

Building Type EOC-Public Safety Answering P	County Yamhill	
Street 130 Ne Baker St		
City McMinnville	State OR	Zip 97128
Latitude 45.20911	Longitude 123.1976	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	-1	0	0	-0.6	0	1.2
Secondary	RM1	2.8	0	0	-1	0	0	-0.6	0	1.2
Tertiary		0	0	0	0	0	0	0	0	0

OSP

Final RVS Score

Final Type	Final Score
C2	1.2

FEMA-154 Collapse Potential

Moderate (>1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	Yes	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		None	
Other: Ornamental Hazard Over Exit		None	
None		None	
			
SE Falling Hazard		NE Elevation View	
		NE Elevation View	
			
NW Building Quality		NW Elevation View	
		SE Falling Hazard	
		S Elevation View	

