

# Yamhill Grade School

Yamhill-Carlton SD 1

Yamh\_sch03A

Building Type	County	
School	Yamhill	
Street		
310 E Main		
City	State	Zip
Yamhill	OR	97148
Latitude	Longitude	
45.34184	123.18617	
Tracking Code	Inspection Date	
RVS in 2006	8/16/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	-0.4	0	0	2.9
Secondary	RM1	2.8	0	-0.5	0	0	-0.4	0	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill Grade School

## Final RVS Score

Final Type	Final Score
RM1	1.9

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Yamhill Grade School

Yamh\_sch03A

Enrollment 425	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1940
Total Area (square ft) 59503	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
Other: Ornamental Hazard Over Exit		None	
Unreinforced Chimneys		None	
			
SW General Site	S Elevation View	S Primary Structural Type	
			
SW Elevation View	SE Elevation View	SW Plan Irregularity Primary	
			
S Falling Hazard chimney	SE Elevation View	SE Falling Hazard Concrete overhang over door	



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Yamhill Grade School

Yamh\_sch03A



NW Elevation View



NW Elevation View



NW Elevation View



SW Elevation View



S Secondary Structural Type

This is in the Mech room



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Yamhill Grade School

Yamhill-Carlton SD 1

Yamh\_sch03B

Building Type School	County Yamhill	
Street 310 E Main		
City Yamhill	State OR	Zip 97148
Latitude 45.34221	Longitude 123.18536	
Tracking Code RVS in 2006	Inspection Date 8/16/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	-0.4	0	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill Grade School

## Final RVS Score

Final Type	Final Score
W2	2.9

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Yamhill Grade School

Yamh\_sch03B

Enrollment 425	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1970
Total Area (square ft) 59503	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
 NE Elevation View		 NW General Site	
		 SW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Yamhill Grade School

Yamhill-Carlton SD 1

Building Type	County	
School	Yamhill	
Street		
310 E Main		
City	State	Zip
Yamhill	OR	97148
Latitude	Longitude	
45.34202	123.18608	
Tracking Code	Inspection Date	
RVS in 2006	8/16/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill Grade School

## Final RVS Score

Final Type	Final Score
W2	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Yamhill Grade School

Yamh\_sch03C

Enrollment 425	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1940	Est. Decade Built 1940
Total Area (square ft) 59503	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			NW Other      NE Elevation View      NW Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Yamhill Grade School

Yamhill-Carlton SD 1

Yamh\_sch03D

Building Type School	County Yamhill	
Street 310 E Main		
City Yamhill	State OR	Zip 97148
Latitude 45.34235	Longitude 123.18581	
Tracking Code RVS in 2006	Inspection Date 8/16/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	2.4	-0.4	0	0	5.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill Grade School

## Final RVS Score

Final Type	Final Score
W2	5.3

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Yamhill Grade School

Yamh\_sch03D

Enrollment 425	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1980
Total Area (square ft) 59503	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards Other: General Other: Ornamental Hazard Over Exit None		Poor Conditions None None None	
			
SW Elevation View	SE Pounding Potential	SW Pounding Potential	
			
N Elevation View	NW Elevation View		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Yamhill Grade School

Yamhill-Carlton SD 1

Yamh\_sch03E

Building Type School	County Yamhill	
Street 310 E Main		
City Yamhill	State OR	Zip 97148
Latitude 45.34245	Longitude 123.18534	
Tracking Code RVS in 2006	Inspection Date 8/16/2006	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	2.4	0	0	0	6.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0



Yamhill Grade School

Final RVS Score

Final Type	Final Score
W1	6.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Yamhill Grade School

Yamh\_sch03E

Enrollment 425	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1980
Total Area (square ft) 59503	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Elevation View			