

Memorial Elementary School

McMinnville SD 40

Yamh_sch11A

Building Type	County
School	Yamhill
Street	
501 W 14th St	
City	State Zip
McMinnville	OR 97128
Latitude	Longitude
45.21851	123.20281
Tracking Code	Inspection Date
Structural Engineering Report	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	0	0	-0.4	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Memorial Elementary School

Final RVS Score

Final Type	Final Score
URM	-0.1

FEMA-154 Collapse Potential

Very High (100%)

No
Planview
Available



OregonGeology

Memorial Elementary School

Yamh_sch11A

Enrollment 585	Year Built (Field Verified)	Year Built (Alt. Source) 1947	Est. Decade Built
Total Area (square ft) 52946	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<hr/> <hr/> <hr/>		<hr/> <hr/> <hr/>	
Falling Hazards		Poor Conditions	
<hr/> <hr/> <hr/>		<hr/> <hr/> <hr/>	
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries