

# Newby Elementary School

McMinnville SD 40

Yamh\_sch12A

Building Type	County
School	Yamhill
Street	
1125 W 2nd St	
City	State Zip
McMinnville	OR 97128
Latitude	Longitude
45.20955	123.20965
Tracking Code	Inspection Date
Structural Engineering Report	9/15/2006

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0



Newby Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)

No  
Planview  
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Newby Elementary School

Yamh\_sch12A

Enrollment 382	Year Built (Field Verified) 1960	Year Built (Alt. Source) 1960	Est. Decade Built
Total Area (square ft) 28006	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	