

Yamhill-Carlton High School

Yamhill-Carlton SD 1

Yamh_sch18A

Building Type	County	
School	Yamhill	
Street		
275 N Maple St		
City	State	Zip
Yamhill	OR	97148
Latitude	Longitude	
45.34353	123.18618	
Tracking Code	Inspection Date	
RVS in 2006	8/16/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	-0.4	0	0	3.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill-Carlton High School

Final RVS Score

Final Type	Final Score
W2	3.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Yamhill-Carlton High School

Yamh_sch18A

Enrollment 438	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1950
Total Area (square ft) 64037	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
	W Elevation View		SW Elevation View
	SW Elevation View		S Primary Structural Type Wood inside window. Shop teacher said the walls are wood framed with steel truss roof.
			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Yamhill-Carlton High School

Yamhill-Carlton SD 1

Yamh_sch18B

Building Type	County
School	Yamhill
Street	
275 N Maple St	
City	State Zip
Yamhill	OR 97148
Latitude	Longitude
45.34349	123.18574
Tracking Code	Inspection Date
RVS in 2006	8/16/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Yamhill-Carlton High School

Final RVS Score

Final Type	Final Score
S3	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Yamhill-Carlton High School

Yamh_sch18B

Enrollment 438	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1970
Total Area (square ft) 64037	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Elevation View	NW Elevation View	NW Plan Irregularity Primary	
			
E Primary Structural Type	W Elevation View	S Elevation View	
			
SW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries