

Amity Elementary School

Amity SD 4J

Yamh_sch24A

Building Type School	County Yamhill	
Street 300 Rice Ln		
City Amity	State OR	Zip 97101
Latitude 45.12246	Longitude 123.2039	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Amity Elementary School

Final RVS Score

Final Type	Final Score
PC1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Amity Elementary School

Yamh_sch24A

Enrollment 335	Year Built (Field Verified) 1983	Year Built (Alt. Source) 1983	Est. Decade Built 1980
Total Area (square ft) 42048	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Primary Structural Type caulked joints		S Building Name	
			
W Elevation View		S Elevation View	
			
NW Elevation View		N Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Amity Elementary School

Amity SD 4J

Yamh_sch24B

Building Type	County	
School	Yamhill	
Street		
300 Rice Ln		
City	State	Zip
Amity	OR	97101
Latitude	Longitude	
45.12265	123.20337	
Tracking Code	Inspection Date	
RVS in 2006	8/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Tertiary		0	0	0	0	0	0	0	0	0


Amity Elementary School

Final RVS Score

Final Type	Final Score
PC1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Amity Elementary School

Yamh_sch24B

Enrollment 335	Year Built (Field Verified) 1983	Year Built (Alt. Source) 1983	Est. Decade Built 1980
Total Area (square ft) 42048	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity)		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Torsion: Eccentric Stiffness None		None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE Primary Structural Type		 N Secondary Structural Type	
 NE Secondary Structural Type		 SE Elevation View	
 W Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Amity Elementary School

Amity SD 4J

Yamh_sch24C

Building Type	County
School	Yamhill
Street	
300 Rice Ln	
City	State Zip
Amity	OR 97101
Latitude	Longitude
45.12247	123.20362
Tracking Code	Inspection Date
RVS in 2006	8/10/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Tertiary		0	0	0	0	0	0	0	0	0


Amity Elementary School

Final RVS Score

Final Type	Final Score
PC1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Amity Elementary School

Yamh_sch24C

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
335	1983	1983	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
42048	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Plan Irregularity Primary		SE Vertical Irregularity Primary	
		SW Other	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries