

Appendix G
Class 1 Buildings, Blank Forms

**Class 1 Building
Project Notification Form**

Agency:		Date submitted:	
Contact person:	E-mail:	Phone:	
Division or user:		ODOE Project ID #:	
Project name:			
Project address:			
City:		ZIP:	
Project Description:			
Energy systems affected:			
Area and Use Information:			
Project type:	<input type="checkbox"/> New construction	R = Renovation	
Total floor area (sq.ft.)	<input type="text"/>	gross heated or cooled	
Affected floor area (sq.ft.)	<input type="text"/>	full area if new, or renovated area	
Construction cost	\$ <input type="text"/>	total budget, not appropriated amount	
Breakdown area by use and schedule; show design occupancy			
Area Breakdown (Square Feet)	Use code	Number of occupants	Occupied Hours/Day Days/Week Weeks/Yr
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Use Codes:			
A = Food/cafeteria, gym/pool/lockers, library/archives, theater/arena		M = shop/retail	
B = Computer center, education, laboratory, office		R = Residential/dorm	
I = Clinic, hospital, jail/prison		S = Warehouse	
Estimated schedule:		Month/Day/Year	
RFP for design services:	<input type="text"/>	Bid date:	<input type="text"/>
Schematic design begins:	<input type="text"/>	Construction begins:	<input type="text"/>
Design development begins:	<input type="text"/>	Construction complete:	<input type="text"/>
Design development complete:	<input type="text"/>		

**Class 1 Building
Project Team Contacts Form**

Agency:		ODOE Project ID#
Project manager:	E-mail:	Phone:
Billing contact:	E-mail:	Phone:
Billing address:		
City:		ZIP:
Architectural firm:		
Managing Architect:	E-mail:	Phone:
Project architect:	E-mail:	Phone:
Mechanical Engineering Plumbing Firm:		
Mechanical Engineer:	E-mail:	Phone:
Electrical Engineer:	E-mail:	Phone:
Lighting designer:	E-mail:	Phone:
Energy Analyst:	E-mail:	Phone:
Commissioning Agent/Verification Provider:		
E-mail:		Phone:
Document Reviewer (for ECM Inclusion):		
E-mail:		Phone:
Other Design Team Member:		
E-mail:		Phone:

Energy Analyst Qualifications Form
<p>Energy Analyst's Name:</p> <p>List the qualifications of the person(s) responsible for the accuracy of the energy model and the Energy Analysis Report:</p>
<p>Description of experience with a computerized, hourly building modeling tool for energy analysis. How current is this experience?</p>
<p>List computer modeling programs with which the modeler has experience including years of experience with each modeling program:</p>
<p>Provide reference contacts for energy modeling experience:</p>
<p>List name(s) of others who will be working on the model and report:</p>
<p>List projects on which the Energy Analyst has performed computer modeling:</p> <p>Attach a sample of Energy Analysis Reports:</p> <p>List any buildings modeled for the SEED program:</p>
<p>Number of years of full time energy modeling experience:</p> <p>Has the Energy Analyst taken the ODOE Energy Modeling Workshop?</p> <p>Date of Workshop</p>

Energy Programming and Design Intent Checklist General Description / Requirements

The following list of energy programming and design intent items should be considered early in the design effort when basic building concepts are being developed. Integration of many of these design concepts is needed early because adoption later in the design is often cost prohibitive or not feasible. Many owner operational requirements and designer design criteria have a significant impact on building energy use and operational costs. Such decisions affect building operating hours, occupant comfort and sizing of energy using equipment.

Information contained in this checklist can be collected from developed programming documents or serve as a reference to what should be included in the programming document. This information needs to be documented so dialog about relevant ECM options can be more clearly defined. Full development of this checklist will evolve as design progresses into schematic and design development phases. It may be necessary to defer decisions on particular efficiency concepts until the energy model is developed in order to address potential energy savings and cost effectiveness.

Excel forms available at <http://www.energy.state.or.us/SEED/Toolbox.htm>

State Energy Efficient Design Energy Programming Considerations		
Project Name:	<input style="width: 100%;" type="text"/>	
Date of Issue:	<input style="width: 20%;" type="text"/>	<input style="width: 80%;" type="text"/>
Fuels and Utilities		
Service	Selection	Name of Utility
Electric	<input checked="" type="checkbox"/>	
Natural Gas	<input checked="" type="checkbox"/>	
Propane	<input type="checkbox"/>	
Fuel Oil	<input type="checkbox"/>	
Steam	<input type="checkbox"/>	
Other	<input type="checkbox"/>	
Electrical Service Voltage:		
	Primary.....	<input type="checkbox"/>
	Secondary.....	<input type="checkbox"/>
Points of service:		
	Centralized / Single Meter.....	<input type="checkbox"/>
	Distributed / Multiple Meter.....	<input type="checkbox"/>
Back-up Systems		
	<u>Electric Stand-by Generator.....</u>	<input type="checkbox"/>
	Systems to be supported:	
	Fire Systems.....	<input type="checkbox"/>
	Selected HVAC.....	<input type="checkbox"/>
	Computers.....	<input type="checkbox"/>
	Elevators.....	<input type="checkbox"/>
	Special Use Equipment.....	<input type="checkbox"/>
	<u>Secondary or Alternate Fuel to Primary Fuel.....</u>	<input type="checkbox"/>
	Systems to be supported:	
	Heating.....	<input type="checkbox"/>
	DHW.....	<input type="checkbox"/>
	Special Use Equipment.....	<input type="checkbox"/>
Comments:		

Building Envelope	
Building Orientation and Shape	
East-West Axis.....	<input type="checkbox"/>
Long and slender shape.....	<input type="checkbox"/>
Enhance Wall Thermal Mass	
Reduction of peak heating and cooling loads.....	<input type="checkbox"/>
Reduction of energy use due to the thermal flywheel effect.....	<input type="checkbox"/>
Daylighting Architectural Features	
Shadings and Overhangs.....	<input type="checkbox"/>
Light Shelves, Clerestories, Skylights.....	<input type="checkbox"/>
Heat Absorption Prevention	
Color selection of roof and wall surfaces.....	<input type="checkbox"/>
Landscape shading.....	<input type="checkbox"/>
Comments:	
Domestic Hot Water (DHW)	
Showers: Number of people and use pattern (describe below)	
Fixtures: Number and assumed diversity factors (describe below)	
Special Equipment: Define water demand and use pattern (describe below)	
Fixture controls	
Manual.....	<input type="checkbox"/>
Spring return.....	<input type="checkbox"/>
Automatic infra-red sensor.....	<input type="checkbox"/>
DHW generation and distribution.....	<input type="checkbox"/>
Sizing criteria: loads, recovery rates, storage capacity	
Comments:	

Equipment Loads	
Office Equipment	<input type="checkbox"/>
Owner supplied electronic office equipment.....	
Sleep Mode, Energy Star or other standard.....	<input type="checkbox"/>
Features set-up and controlled by Owner.....	<input type="checkbox"/>
Occupancy based controls.....	<input type="checkbox"/>
After hours switchable loads.....	<input type="checkbox"/>
Large equipment or system loads recommended for gas firing	
Space heat.....	<input type="checkbox"/>
DHW heaters.....	<input type="checkbox"/>
Food service equipment	
Grills, fryers, steam kettles, etc.....	<input type="checkbox"/>
Dishwasher booster heaters.....	<input type="checkbox"/>
Labs equipment	
Autoclaves.....	<input type="checkbox"/>
Steam generators.....	<input type="checkbox"/>
Other.....	<input type="checkbox"/>
Comments:	
Lighting	
Task lighting, lower ambient light levels.....	<input type="checkbox"/>
Light-colored interior finishes for walls, partitions and furniture....	<input type="checkbox"/>
Define interior and exterior light sources	<input type="checkbox"/>
Define fixture types	<input type="checkbox"/>
Define fixture lamp sources	<input type="checkbox"/>
Comments:	

Mechanical Systems		
Distributed mechanical equipment integrated into packaged roof-top equipment.....		<input type="checkbox"/>
Central mechanical equipment served by boiler(s) and chiller(s).....		<input type="checkbox"/>
DHW generation and distribution.....		<input type="checkbox"/>
Special use HVAC requirements		
Computer server room.....		<input type="checkbox"/>
Telecom switch and electronics room.....		<input type="checkbox"/>
Art gallery.....		<input type="checkbox"/>
Laboratorium.....		<input type="checkbox"/>
Natatorium.....		<input type="checkbox"/>
Kitchen.....		<input type="checkbox"/>
Gymnasium.....		<input type="checkbox"/>
Other.....		<input type="checkbox"/>
Maintenance Issues		
Longevity		
Comments:		
Ventilation	Mechanical.....	<input type="checkbox"/>
	Natural.....	<input type="checkbox"/>
	Hybrid System.....	<input type="checkbox"/>
	High Occupancy Areas.....	<input type="checkbox"/>
Comments:		

Class 1 Building ECM Checklist

Instructions

The ECM Checklist makes it easier to track ECMs through the analysis process. The energy analyst submits the ECM Checklist two weeks before the scoping meeting. ECMs may be added to the checklist.

An example of an ECM listing follows:

<u>Status Code</u>	<u>ID</u>	<u>Potential ECMs</u>
B A N/A	E111	Add ceiling/roof insulation

Status codes indicate the phase of analysis or recommendation for each ECM. Check the boxes under the appropriate status code as the analysis progresses. Codes include:

- B Baseline. The ECM is included in the building baseline design.
- A Analyzed. The ECM is selected for analysis at the scoping meeting.
- N/A Not applicable.

The ID code includes a category letter and a three-digit number. “R” listed at end of three-digit number indicates ECM is primarily applicable to renovation projects.

Put an “X” under the appropriate code for each ECM.

B = Baseline
A = Analyzed
N/A = Not Applicable

Project Name:					
E100 Envelope					
Status Code					
B	A	N/A	ECM#	Potential ECMs	ECM Description
			E110	Reduce Heat Losses	
			E111	Ceiling/roof insulation	
			E112	Wall insulation	
			E113	Floor/slab insulation	
			E114	Fan penthouse insulation	
			E115	Windows:	
			A	Thermal break in metal window frames	
			B	Wood, vinyl, or fiberglass window frames	
			C	Argon gas-filled glazing panels	
			D	High-performance low-e (e = 0.05) coating	
			E	Tinted glazing or reflective coatings	
			E120	Reduce Heat Gain	
			E121	Architectural shading and overhangs	
			E122	Window sizing and orientation	
			E123	Cool roof, green roof	
			E130	Reduce Infiltration	
			E131	Seal openings at penetrations of building envelope	
			E132	Air-lock vestibule or revolving doors	
			E190	Other Envelope Measures	

L100 Lighting					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			L110	Efficient Lighting Systems	
			L111	Optimize fixture layout, spacing & orientation	
			L112 R	Delamp overlit areas	
			L113	Efficient Fixture Selection, (fixture CU)	
			L114	Optimize Ballast Selection	
			L115	Efficient Lamp Selection	
			A	Compact fluorescents in place of incandescents	
			B	Incandescent IR Halogen vs standard PAR lamps	
			C	Ceramic Metal Halide vs standard PAR lamps	
			D	High-output linear fluorescents in place of HID fixtures	
			E	Pulse Start Metal Halides vs standard Metal Halides	
			F	LED technology, exit signs and other applications	
			L116	Exterior LPD at or below ASHRAE-90.1-2004	
			L120	Lighting Controls	
			L121	Occupancy sensors (exceeding code requirements)	
			L122	Selective switching, (control of multiple lamps within fixture)	
			L123	Egress lighting scheduled off during unoccupied periods	
			L124	Exterior lighting controls (exterior lights extinguished after occupied period (i.e. 9PM - 5AM))	
			L130	Optimize Daylighting	
			L131	Continuous dimming controls	
			L132	On/off daylighting control	
			L133	Separate circuits for zoning flexibility in daylit zones	

			L190	Other Lighting Measures	
W100 Domestic Hot Water (DHW)					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			W110	Reduce DHW Distribution Losses	
			W111	Install return-line aquastat (not required by code)	
			W120	Efficient DHW Generation	
			W121	90%-plus condensing hot water heaters	
			W122	Summer water heater or small boiler	
			W123	Preheat DHW with reclaimed waste heat (i.e. chiller condenser, direct-contact boiler stack economizer, 24/7 computer server room AC unit)	
			W124	Solar-assisted water heater	
			W125	Heat pump water heater	
			W130	Process Related DHW Use	
			W131	Institutional laundry water reuse system	
			W132	Horizontal axis washing machines	
			W140	Heat Recovery	
			W141	Waste water heat recovery, i.e.GFX system	
			W190	Other DHW Measures	
F100 HVAC - Unitary Equipment					
Status Code					
B	A	N/A	ECM#	Potential ECMs	

			F110	Unitary Equipment	
			F111	Condensing furnaces	
			F112	Cooling-unit efficiency	
			F113	Air-to air heat pump efficiency	
			F114	Water-source heat pump	
			F115	Radiant heating	
			F116	Other HVAC general/unitary measures	
A100 HVAC - Air Distribution					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			A110	Reduce Airflow Rates	
			A111	Variable airflow with VFD	
			A112	Cold air distribution	
			A120	Reduce Fan Pressure Resistance	
			A121	Minimize fan unit static pressure-losses: air filters, cooling and heating coils, enlarge cabinet size.	
			A122	Minimize duct static pressure-losses: enlarging ducting & optimize fittings	
			A130	Reduce Ventilation Loads	
			A131	Separate make-up air units for high-ventilation areas	
			A132	Heat recovery (air-to- air, run-around loop, heat wheel)	
			A140	Reduce Air Leaks and Heat Losses	
			A141	Install low-leakage dampers	
			A150	Fan Systems and Delivery Systems	
			A151	Specify efficient fans and select efficient size fan wheel	

			A152	Separate HVAC units for perimeter and core zones	
			A153 R	Change constant air-volume reheat to VAV reheat	
			A154 R	Change multi-zone or dual duct to VAV	
			A155	Parallel fan power VAV boxes to reduce perimeter zone reheat	
			A190	Other HVAC - Air Distribution ECMs	
D100 HVAC - Steam and Water Distribution					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			D110	Reduce Energy Losses	
			D111	Steam trap monitoring and repair program	
			D112	Insulate piping and valve bodies	
			D120	Reduce System Flow and Pressure Resistance	
			D121	Variable primary pumping with VFD	
			D122	Increase cooling coil temperature difference	
			D123	Increase Heating coil temperature difference	
			D124	Reduce pump head pressure	
			D190	Other Steam or Water Distribution System	
T100 HVAC Controls					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			T110	Air-Side Control Strategy	
			T111	Airflow and temperature setback in unoccupied areas through occupancy sensors or schedules	
			T112	Variable ventilation based on CO ₂ control	

			T113	Night-flush cooling cycle	
			T120	Water Side Control Strategy	
			T121	Time clock and OSA lockout control of heating and cooling pumps	
			T130	Misc. Controls	
			T131	Isolate large sheddable loads and install automated controls to limit electrical demand	
			T190	Other HVAC Controls	
C100 Cooling Plant					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			C110	More Efficient Cooling Equipment	
			C111	Select efficient kW/ton chillers: 1) centrifugal, 2) screw, 3) reciprocating	
			C112	Select chiller size(s) for efficient sequencing	
			C113	Optimization of chiller sequencing controls	
			C114	Central Heat Pump	
			C120	Alternate Cooling	
			C121	Water-side free cooling: cooling tower and P&F heat exchanger	
			C122	Heat recovery chiller	
			C130	Increase Condenser Efficiency	
			C131	Specify more efficient cooling tower to reduce LWT	
			C132	Water-cooled versus air cooled	

			C133	Evaporative-cooled versus air cooled	
			C134	Condenser water reset controls	
			C190	Other Cooling Plant Measures	
H100 Heating Plant					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			H110	Improve Boiler Efficiency	
			H111	Specify efficient boilers	
			H112	Select boiler size(s) for efficient sequencing	
			H113	Optimization of boiler sequencing controls	
			H114	Modulating burner control, specify high turn-down ratio (>5:1)	
			H115	Improve draft controls: turbulators, barometric dampers	
			H116 R	Improve combustion by reducing excess air with O2 trim controls	
			H117	Boiler flue heat recovery to preheat combustion air or feed water	
			H118R	Recover heat from boiler blow-down	
			H120	Alternate Heating Systems	
			H121	Condensing hydronic boiler, design at lower supply/return water temp. i.e 140 F supply and 110 F return water temp.	
			H122	Water-source or ground-source heat pumps	
			H190	Other Heating Plant Measures	
K100 Hood and Make-up Systems for Kitchens, Labs, Shops, Process Equipment, etc.					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			K111	Minimize exhaust hood airflows, i.e. low flow hoods	

			K112	Minimize exhaust hood run time	
			K113	Separate make-up air unit set at lower temperature	
			K190	Other Hood and Make-up Systems	
S100 Swimming Pools					
Status Code					
B	A	N/A	ECM#	Potential ECMs	
			S111	Elevate air temperature to reduce pool evaporation rates	
			S112	Air-to-air heat recovery of ventilation air	
			S113	De-humidification heat recovery	
			S114	Variable ventilation based on advanced climate controls sensing humidity, indoor/outdoor/dew-point temperatures	
			S115	Lower ventilation rates during unoccupied hours	
			S116	Low pressure-drop pool water filters/strainers	
			S117	Two-speed circulation/filtration pumping (occupied/unoccupied modes)	
			S190	Other Swimming Pool Measures	
P100 Power/Electrical Distribution					
Status Code					
B	A	NA	ECM#	Potential ECMs	
			P110	Premium-efficiency motors	
			P111	In excess of code (Consortium for Energy Efficiency) i.e.fans, pumps, etc.	
			P120	Vertical Transport	
			P121	Hydraulic elevator pump/motor efficiency opportunities	

			P122	Traction Elevator	
			P130	Server and Telecom Rooms	
			P131	Multiple small compressors for efficiency and redundancy	
			P132	Air side economizer cooling	
			P133	Water side economizer cooling	
			P134	Wider deadband for humidity and temperature control (based on actual design requirements)	
			P140	Refrigeration Systems	
			P141	Select units with high efficiency compressors	
			P142	Increase condensing efficiency and optimize capacity control	
			P143	Install floating-head pressure controls	
			P150	Appliances	
			P151	Residential Energy Star- refrigerator, dishwashers, washing machines, etc	
			P152	Commercial Equipment- Pcs, LCD Monitors, copiers, vending misers	
			P190	Other Power Measures	

Scoping Process Information Checklist

Project name: _____

Submit this checklist and all listed items to scoping meeting attendees two weeks before the scoping meeting.

A. Information provided by the design team:

- Schematic plans, including floor plans, sections, and elevations of the building, sufficient for modeling input
- Description of building envelope components
- Description of the proposed building mechanical and electrical systems, including preliminary size selection and efficiencies of all major equipment
- Lighting strategies and connected lighting load
- Information adequate to verify compliance with Chapter 13 of the *State of Oregon Structural Specialty Code*
- Connected equipment load and specialized equipment requirements
- Description of operating criteria and schedules

B. Information provided by the energy analyst and design team:

- Results of preliminary modeling if any.
- Descriptions of ECMs that will be included in the Proposed Baseline building
- Descriptions of potential ECMs suggested for inclusion in the building
- Completed ECM checklist

Checklist for Appendices to the Preliminary Energy Analysis Report

Project name: _____

The *Preliminary Energy Analysis Report* includes material adequate to review all ECMs for individual cost-effectiveness.

- A copy of the *ECM Checklist* with notations for baseline and suggested ECMs.
- Narrative describing the Proposed Baseline Building and the Code Building, the analyzed ECMs, and the recommended ECM package.
- Tables 2-2, 3-1, 4-1, and 4-2,
- Preliminary ECM calculations, estimates, and justification for eliminated ECMs, Including *Preliminary ECM Analysis* worksheets for all eliminated ECMs.
- Cost estimates for all ECMs analyzed
- Cost-Effectiveness Analysis* worksheets
 - Individual ECMs analyzed
 - ECM packages
- Electronic version of the building model inputs.
- A list of modeling inputs and values that have been changed for each building model.
- Summary output report(s) for the Code Building, the Proposed Baseline Building, all ECM runs, and the SEED Building, including:
 - A breakdown of energy usage by at least the following components: lights, internal equipment loads, service water heating equipment, space heating equipment, space cooling and heat rejection equipment, fans, and other HVAC equipment (such as pumps).
 - The amount of time any loads are not met by the HVAC system for both the proposed design and baseline building design
 - An explanation of any warning messages noted in the simulation program output. Electronic copies of complete model outputs are required.
- Current energy rate schedules. Where energy is received from a state-operated central plant, cite the rate source used.
- Manual savings calculations if any.
- Building-model HVAC zone map

- Miscellaneous information: equipment catalog sheets, test reports, etc.
- Modeled energy use of SEED building showing electrical and fossil fuel use on a monthly basis.
- Building metering plan
- Performance Verification Plan

Blank Cost-Effective Analysis Spreadsheet forms are available at:
<http://www.energy.state.or.us/SEED/Toolbox.htm>

Cost-Effective Analysis Spreadsheet

<i>PRELIMINARY ECM COST EFFECTIVENESS ANALYSIS</i>				<i>State Energy Efficient Design</i>			
Building: <input style="width: 150px;" type="text"/>		By: <input style="width: 100px;" type="text"/>		Agency: <input style="width: 150px;" type="text"/>			
ECM Name: <input style="width: 300px;" type="text"/>				ECM Life: <input style="width: 100px;" type="text"/> YRS			
ECM DESCRIPTION (Compare Baseline Conditions with ECM Changes):							
BASELINE CONDITIONS				ECM CHANGES			
<div style="border: 1px solid black; width: 100%; height: 100%;"></div>				<div style="border: 1px solid black; width: 100%; height: 100%;"></div>			
ECM MAINTENANCE AND OPERATING COST IMPACT							
ITEMS				ANNUAL SAVINGS		ANNUAL INCREASE	
<div style="border: 1px solid black; width: 100%; height: 100%;"></div>				<div style="border: 1px solid black; width: 100%; height: 100%;"></div>		<div style="border: 1px solid black; width: 100%; height: 100%;"></div>	
If page 2 is used, enter Replacement and Periodic Maintenance from page 2:				RM1		RM2	
TOTAL = (SAVINGS) - (INCREASE) = <input style="width: 100px;" type="text" value="\$0"/>				MAINT		TOTALS: <input style="width: 100px;" type="text" value="\$0"/>	
				TOTALS		<input style="width: 100px;" type="text" value="\$0"/> <input style="width: 100px;" type="text" value="\$0"/>	
PRESENT VALUE COST							
CAPITAL COST OF ITEMS:				BASELINE DEDUCTS		ECM COSTS	
<div style="border: 1px solid black; width: 100%; height: 100%;"></div>				<div style="border: 1px solid black; width: 100%; height: 100%;"></div>		<div style="border: 1px solid black; width: 100%; height: 100%;"></div>	
TOTAL ECM COSTS AND BASELINE DEDUCTS				<input style="width: 100px;" type="text" value="\$0"/>		<input style="width: 100px;" type="text" value="\$0"/>	
DESIGN COST INCREASE (if any) <input style="width: 100px;" type="text" value="\$ -"/>		(ECM COST) - (DEDUCTS) + (DESIGN) =				<input style="width: 100px;" type="text" value="\$0"/> COST	
NON ENERGY O&M COST INCREASE <input style="width: 100px;" type="text" value="\$ -"/>		MAINT. <input style="width: 100px;" type="text" value="\$ -"/>		UPW* <input style="width: 100px;" type="text" value="#N/A"/>		PV O&M COST <input style="width: 100px;" type="text" value="#N/A"/>	
*USE UPW FOR YEAR EQUAL TO ECM LIFE				Total PV cost		<input style="width: 100px;" type="text" value="#N/A"/> PVC	
PRESENT VALUE SAVINGS							
ANNUAL ENERGY SAVINGS							
Fuel Type	Units	MMBtu	Cost \$/unit	Annual \$	FEF*	PV Savings	
Electricity kWh	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="\$0"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>	
Natural Gas therms	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="\$0"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>	
#2 Oil or Diesel gal	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="\$0"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>	
Total Energy Savings		<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="0"/>	<input style="width: 50px;" type="text" value="\$0"/>	<input style="width: 50px;" type="text" value="#VALUE!"/>		
*THESE ARE VALUES FOR FEF OR UPW FOR YEAR EQUAL TO ECM LIFE							
Total O&M Savings:		<input style="width: 50px;" type="text" value="\$ -"/>	x	<input style="width: 50px;" type="text" value="#N/A"/>	PV ANNUAL SAVINGS <input style="width: 50px;" type="text" value="#N/A"/>		
Total Annual Savings (Energy + Maint.)		<input style="width: 50px;" type="text" value="\$ -"/>	Total PV Savings			<input style="width: 50px;" type="text" value="#VALUE!"/> PVS	
COST EFFECTIVENESS SUMMARY							
Net Present Value Savings		PVS <input style="width: 50px;" type="text" value="#VALUE!"/>	-PVC	<input style="width: 50px;" type="text" value="#N/A"/>	= <input style="width: 50px;" type="text" value="#VALUE!"/> NPV		
Benefit to Cost Ratio		PVS <input style="width: 50px;" type="text" value="#VALUE!"/>	/ PVC	<input style="width: 50px;" type="text" value="#N/A"/>	= <input style="width: 50px;" type="text" value="#VALUE!"/> BCR		
RESULT OF PRELIMINARY ECM ANALYSIS							
<input checked="" type="checkbox"/> Cost Effective - Include in initial ECM Package		<input type="checkbox"/> Potential - Add to ECM Package		<input type="checkbox"/> Non Cost-Effective BCR < 1.0, or other reason			

Cost-Effective Analysis Spreadsheet

PRELIMINARY ECM COST EFFECTIVENESS ANALYSIS (Page 2) *State Energy Efficient Design*

Building: By: Agency:

ECM Name: ECM Life: YRS

Use this form only when ECM life is significantly different from baseline system life and there are significant differences between the ECM and Baseline in either periodic maintenance or replacement costs. Baseline Life: YRS

AVOIDED BASELINE REPLACEMENTS
Include only major replacements at end of baseline system life

	ITEM COST
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>

Present Value of Replacements (net of salvage value) $\frac{10}{15} \times \$0 \times 0.56 = \0

AVOIDED BASELINE PERIODIC MAINTENANCE

BASELINE PERIODIC MAINTENANCE ITEMS	OCCURS IN YEAR	CURRENT \$ COST	SPW AT YEAR	PV COST CURRENT \$
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	× 0.00	= 0
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	× 0.00	= 0
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	× 0.00	= 0

SPW is the Single Present Worth factor from Discount Factor Tables for year periodic maintenance occurs in.

Present value of Baseline periodic maintenance: PM-PV1

ADDED ECM PERIODIC MAINTENANCE

ECM PERIODIC MAINTENANCE ITEMS	OCCURS IN YEAR	CURRENT \$ COST	SPW AT YEAR	PV COST CURRENT \$
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	× 0.00	= 0
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	× 0.00	= 0
<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	<input style="width: 100%; height: 20px;" type="text"/>	× 0.00	= 0

SPW is the Single Present Worth factor from Discount Factor Tables for year periodic maintenance occurs in.

Present value of ECM periodic maintenance: PM-PV2

REPLACEMENT AND PERIODIC MAINTENANCE IMPACT (Enter on page 1 under O&M Cost Impact)

Annual Savings $\frac{\text{REP-PV1} + \text{PM-PV1}}{\text{ECM UPW}} = \frac{\$0 + \$0}{15.6} = \0 RM1

Annual Increase $\frac{\text{REP-PV2} + \text{PM-PV2}}{\text{ECM UPW}} = \frac{\$0 + \$0}{15.6} = \0 RM2

ECM UPW is the Uniform Present Worth factor from Discount Factor Tables for ECM life.

Final Energy Analysis Report Review Checklist

Project: _____ Energy Analyst _____

Report Date: _____ Reviewed By: _____ Review Date: _____

Section 1 -- Executive Summary		Accept	Provide	Revise
1a	Facility description and analysis process			
1b	Table 1-1 -- ECM Package Analysis Summary			
1c	Brief description of recommended ECMs and ECM package			
1d	Description of other results			
1e	List of all ECMs considered			
Comments				
Section 2 – Proposed Baseline Building Description		Accept	Provide	Revise
2a	Building description			
2b	Capacity and efficiency for all systems			
2c	Energy analysis description			
2d	Table 2-1—Baseline ECMs			
2e	Table 2-2 – Proposed Baseline Building Energy Use Summary			
2f	Discussion of modeling results			
2g	List of ECMs in Proposed Baseline Building			
Comments				
Section 3 – Preliminary ECM Analysis		Accept	Provide	Revise
3a	Table 3-1 -- Preliminary ECM Savings Analysis			
3b	Description of cost-effective ECMs			
3c	Description of analyzed ECMs that are not cost effective			
3d	Discuss recommended ECM package			
3e	Table 4-2 -- ECM Package Savings Compared to Code Building			
Comments				

**Final Energy Analysis Report
Review Checklist**

Project: _____

Page 2

Section 4 – Code Building Description		Accept	Provide	Revise
4a	Describe differences between Proposed Baseline Building and Code Building			
4b	List ECMs removed from Proposed Baseline Building to form Code Building			
4c	Table 4-1 – Code Building Energy Use Summary			
Comments				
Section 5—Final ECM Package Analysis		Accept	Provide	Revise
5a	Discussion of recommended ECM package, agency comments, and reasons for eliminating cost-effective ECMs			
5b	Update changes to previous sections based on review meeting..			
5c	Description of ECM package, implementation, feasibility, related baseline condition, ECM components, etc.			
5d	Table 4-2 -- Recommended Package (SEED Bldg.)ECM Interactive Savings			
5e	Table 5-1 – SEED Building Energy Use Summary			
5f	Discussion of other results			
Comments Add PO spreadsheet in electronic and print form				

Checklist for Appendices to the Energy Analysis Report**Project name:** _____

Complete this checklist to ensure all required appendices are included with the *Final Energy Analysis Report*. Attach a copy of the checklist to the final report.

Update all items listed in the Preliminary Energy Analysis Checklist

Meeting minutes:

- Scoping meeting
- ECM review meeting