


ESTERSON Sarah * ODOE

From: Stippel, Joe <JStippel@idahopower.com>
Sent: Monday, March 23, 2026 6:17 AM
To: ESTERSON Sarah * ODOE
Cc: Adams, Walter; Patrick G Rowe; Ottenlips, Michael
Subject: B2H ADR 0004

Sarah,

As discussed in the 3/20/2026, IPC is electing to no longer proceed with proposed change 02, UN 536-Mod. There are existing guy wires from a non-Facility transmission line, an obstruction not accounted for in the original design. Due to a delay in approval of ADR 4, the construction team has elected to move forward with the existing access and adjust around the obstruction. Although this is not the preferred approach, given the delays, construction has elected to move forward to hold the construction schedule.



(this was stuck in my outbox Friday, sorry for the delay).

Joe

Joe Stippel, PE

500kV PROJECTS LEADER

Idaho Power | 500kV Projects

Office 208-388-2675 | Mobile 208-705-7525

Email JStippel@idahopower.com

idahopower.com

IDAHO POWER LEGAL DISCLAIMER

This transmission may contain information that is privileged, confidential and/or exempt from disclosure under applicable law. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution, or use of the information contained herein (including any reliance thereon) is STRICTLY PROHIBITED. If you received this transmission in error, please immediately contact the sender and destroy the material in its entirety, whether in electronic or hard copy format. Thank you.
